




GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



FORMULE - 18(2)

F O R M - (G)

No. F&ES/FPW/ 5 (2022) 666/22

Dated Guwahati the 19/5/22

To,

The Chief Executive Officer,
For All Saints Diocesan School,
Tezpur, Dist:- Sonitpur, Assam.

RENEWAL OF NO OBJECTION CERTIFICATE IN RESPECT OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN THE ALL SAINTS DIOCESAN SCHOOL LOCATED AT TEZPUR, DIST:- SONITPUR, ASSAM.

With reference to your completion report under No. Nil Dated 18.04.2022 and on the basis of the Inspection Report submitted by Sr. Station Officer, Ringhamdao Kemprai, I hereby certify that the building as per description below at Dag No. 2086, 2091, 2013 Patta No. 834, 774 Mouza Mahabhairab, (Place- Tezpur, Sonitpur) has been inspected in respect of implementation of inbuilt Fire Fighting/ Fire Prevention/ Escape means measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has No Objection in its occupation /utilization for the purpose of SCHOOL subject to conditions mentioned below.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR:-

1. Floor area:- 1089.82 m²

2. Purpose of utilization:-

For School Purpose.

Details of Fire Fighting measures found in working condition:

1. Manually Operated Electric Fire Alarm system
2. Fire Extinguishers- 17 Nos.
3. Water Reservoir
4. Terrace Water Tank

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services, Assam
Guwahati.
Dated Guwahati the 19/5/22

NO. F&ES/FPW/

Copy to:-

1. The Deputy Commissioner, Sonitpur, Assam for information.
2. The Superintendent of Police, Sonitpur, Assam for information.
3. The Chairman, Tezpur Municipal Board, Assam for information.
4. The Sr. Station Officer, Tezpur F&ES Station, for information and necessary action.

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

CONDITIONS:-

1. The N.O.C. is valid up to: - 31.03.2023
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
7. The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services, Assam
Guwahati.